

HIREDPOT
Brick Elevator – HAZARD ASSESSMENT

<u>The Identified Hazard</u>	<u>Risk Yes/ No</u>	<u>The Proposed Method of Control Measure</u>	<u>Are The Control Methods Practical</u>
<i>Persons could be injured if the operator performs duties that are not his responsibility and beyond the scope of his technical capabilities.</i>	Yes	<i>The operator should be adequately trained or licensed. The operator must not carry out any work that is outside his normal duties and report any matters of concern to his supervisor.</i>	Yes
<i>Crushing due to overloading or failure of the brick elevator.</i>	Yes	<i>Do not overload the brick elevator. Daily inspection of the machine is required or before each use. Ensure that the machine is set up correctly.</i>	Yes
<i>Crushing due to falling bricks, or other materials.</i>	Yes	<i>Ensure the machine is set up on level ground. Do not overload. Do not stack bricks on top of each other. Barricade around base of unit, to stop people from walking underneath.</i>	Yes
<i>Electrocution</i>	Yes	<i>Ensure the unit is not operated in close proximity to any live wires or electrical hazards.</i>	Yes
<i>Persons could be injured if the machine operator is unfamiliar with typical unsafe conditions and hazards that could affect the safe operation of the unit.</i>	Yes	<i>The operator should be trained in determining unsafe conditions and hazards that are relative to the machine's safe operation.</i>	Yes
<i>Persons could be injured if personal protective equipment is not available or being used when working in an unsatisfactory environment e.g. noise, heat, fumes, etc.</i>	Yes	<i>Instruct the operator to ensure that appropriate personal protective equipment is available and is in good condition prior to commencing work.</i>	Yes

Mandatory Personal Protective Equipment:



Foot
Protection



Head
Protection

Customer Signature: _____