

Generator

IDENTIFIED HAZARD	RISK (YES / NO)	PROPOSED METHOD OF CONTROL MEASURE	ARE THE CONTROL METHODS PRACTICAL?
Persons could be injured if the operator performs duties that are not his responsibility and beyond the scope of his technical capabilities.	YES	The operator should be adequately trained or licensed. The operator must not carry out any work that is outside his normal duties and report any matters of concern to his supervisor.	YES
Persons could be injured as a result of electrocution.	YES	Do not use in wet or damp conditions. Do not use with faulty leads or plugs. Ensure equipment is tested/ tagged for compliance with electrical safety testing requirements.	YES
Persons could be injured or affected by fumes.	YES	Generator should only be operated in a well ventilated area.	YES
Manual handling hazard.	YES	Use correct lifting techniques.	YES
Persons could be injured if they come into contact with hot or moving parts.	YES	The operator should let the engine cool down before attempting any maintenance. Avoid contact with hot components. The operator should not remove any protective guards.	YES
Persons could be injured resulting from explosion or fire from fuel vapours.	YES	Do not refuel when hot or running. Ensure fuel cap is correctly refitted and check for fuel spill or leaks before operation.	YES
Persons could be injured if the machine operator is unfamiliar with typical unsafe conditions and hazards that could affect the safe operation of the unit.	YES	The operator should be trained in determining unsafe conditions and hazards that are relative to the machine's safe operation.	YES

MANDATORY PERSONAL PROTECTIVE EQUIPMENT



Customer Signature: _____ Date: _____